

CWS Door Replacement
Bid Walk Clarifications and Questions Received as of 4/27/16
Addendum #1

Questions:

Q: Adequate Signage should be affixed to door or near, that indicates how to operate the door.

A: County will provide all signage

Q: Sensors will engage once the door control is activated and sensors will remain on until it is successfully closed.

A: The County agrees that this is the best method for door control.

Q: Will the door will have an electric lock with card reader control

A: Yes.

Q: What does the 3 position knob have to be? Switch, key, or push?

A: Any of the above are fine.

Q: Exhibit D. I am not sure what you are looking for here. Installed price / Is that the total cost of the job ? Or just the install labor portion? Pricing /pricing of labor rates or what?

A: We are looking for the complete cost of installation for a complete package as outlined in the Invitation for Bid and addendums.

Q: Door Standards: CBC, ANSII, ADA.

A: Vendor to ensure that all standards are met for the installation of the new door and door controls.

Clarifications:

1. County to provide conduit. Vendor to provide the power box.
2. Doors should be a single/partial breakout.
3. Glass shall be smoke glass to match.
4. Only the door shall be replaced. Reuse sidelight.
5. Adjust threshold at transition to make ADA compliant.
6. Confirmed that all work shall be proposed as after hours, prevailing wage.